



MODEL NO. _____ A950-48
 CAPACITY _____ 45,000 GR.
 * NORMAL FLOW _____ 11 GPM @ 15 PSI DROP
 * PEAK FLOW _____ 16 GPM @ 25 PSI DROP
 BW RATE _____ 1.7 GPM
 MINERAL TANK _____ 10" DIA X 54" HEIGHT
 MEDIA VOL. _____ 1.50 CU/FT
 BRINE TANK _____ 18" DIA X 40" HEIGHT
 SALT CAPACITY _____ 320 LBS

ACCESSORIES:
 WATER METER _____ INTERNAL TURBINE

WEIGHT:
 SHIPPING _____ 120 LBS
 OPERATING _____ 710 LBS

PIPE SIZE:
 INLET _____ 1" Sweat
 OUTLET _____ 1" Sweat
 DRAIN _____ 1/2" Tube
 BRINE _____ 3/8" Tube

NOTES:
 DASHED PIPING, FITTINGS AND VALVES SUPPLIED BY OTHERS.
 THIS SYSTEM USES TANKS THAT MUST NOT BE SUBJECTED TO A VACUUM. INSTALL A VACUUM BREAKER PER DRAWING.
 ALSO AVAILABLE IN 3/4" PIPE CONNECTIONS
 DO NOT SOLDER PIPES WHILE CONNECTORS ARE ATTACHED TO THE CONTROL VALVE

* QUALITY OF WATER MAY VARY DEPENDING UPON FLOW RATE AND WATER CONDITIONS

DIMENSIONS:

- A: _____ 64"
- B: _____ 10"
- C: _____ 18"
- D: _____ 40"

All Dimensions are +/- 2"



THIS DRAWING AND ALL OF THE DESIGN INFORMATION ARE THE SOLE PROPERTY OF THE SYSTEM MANUFACTURER. THIS DRAWING IS NOT TO BE DISCLOSED OR COPIED WITHOUT THE WRITTEN AUTHORIZATION FROM THE SYSTEM MANUFACTURER.

SINGLE METERED SYSTEM 4			
GENERAL ARRANGEMENT			
DRAWN BY		DATE	DWG. NO.
SCALE		10/01/19	A950SM.tif
CHECKED BY			
APPROVED BY			