



MODEL NO. \_\_\_\_\_ A940-32  
 CAPACITY \_\_\_\_\_ 27,000 GR.  
 \* NORMAL FLOW \_\_\_\_\_ 9 GPM @ 15 PSI DROP  
 \* PEAK FLOW \_\_\_\_\_ 14 GPM @ 25 PSI DROP  
 BW RATE \_\_\_\_\_ 1.3 GPM  
 MINERAL TANK \_\_\_\_\_ 8" DIA X 44" HEIGHT  
 MEDIA VOL. \_\_\_\_\_ .90 CU/FT  
 BRINE TANK \_\_\_\_\_ 18" DIA X 33" HEIGHT  
 SALT CAPACITY \_\_\_\_\_ 240 LBS

**ACCESSORIES:**

WATER METER \_\_\_\_\_ INTERNAL TURBINE

**WEIGHT:**

SHIPPING \_\_\_\_\_ 80 LBS

OPERATING \_\_\_\_\_ 520 LBS

**PIPE SIZE:**

INLET \_\_\_\_\_ 3/4" Sweat

OUTLET \_\_\_\_\_ 3/4" Sweat

DRAIN \_\_\_\_\_ 1/2" Tube

BRINE \_\_\_\_\_ 3/8" Tube

**NOTES:**

DASHED PIPING, FITTINGS AND VALVES SUPPLIED BY OTHERS.

ALSO AVAILABLE IN 1" PIPE CONNECTIONS

DO NOT SOLDER PIPES WHILE CONNECTORS ARE ATTACHED TO THE CONTROL VALVE

\* QUALITY OF WATER MAY VARY DEPENDING UPON FLOW RATE AND WATER CONDITIONS

**DIMENSIONS:**

- A: \_\_\_\_\_ 54"
- B: \_\_\_\_\_ 8"
- C: \_\_\_\_\_ 18"
- D: \_\_\_\_\_ 33"

All Dimensions are +/- 2"



THIS DRAWING AND ALL OF THE DESIGN INFORMATION ARE THE SOLE PROPERTY OF THE SYSTEM MANUFACTURER. THIS DRAWING IS NOT TO BE DISCLOSED OR COPIED WITHOUT THE WRITTEN AUTHORIZATION FROM THE SYSTEM MANUFACTURER.

SINGLE TIMECLOCK SYSTEM 4			
GENERAL ARRANGEMENT			
DRAWN BY		DATE	DWG. NO.
SCALE		10/01/19	A960SM.tif
CHECKED BY			
APPROVED BY			